

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,  
STRUCTURAL ENGINEER, CHARTERED ENGINEER  
REGISTERED&APPROVED ENGINEER  
BY THE BOARD OF ENGINEERS, TAMIL NADU.  
PANEL ENGINEER CLASS IA, KANCHEEPURAM DISTRICT  
Ref: Collector, Kpm, Lr. No: RC 23640/2011/M1 Dated 19.05.2012

Res: 50-A,3<sup>rd</sup> Street, S.S. Nagar.  
Palanipet, Arakkonam - 631002

Off: No. 4, Vanthavasi Road, Gandhi Nagar,  
Kanchipuram - 631501


Cell: 9443106470, 8056631312  
Email : dnatarajan8@gmail.com


**STRUCTURAL SOUNDNESS CERTIFICATE RELATING TO SCHOOL**  
**STATEMENT ACCOMPANYING FORM - A**

1. Name of the school and  
Door no of the Building : **SAN ACADEMY**  
Service Road (200 ft Bypass), Tambaram West  
Tambaram Taluk, Chengalpattu District - 600045.
2. Location (street No. Ward No.  
Name of place, ie., Corporation,  
Municipality/ Panchayat Union/  
Panchayat/Township/Cantonment : S. F. Nos. 38/2B4A, 2B4B, 2B5, 39/3A1A; T.S. No. 1/8 & 1/9  
Ward : D; Block No. 8  
Service Road (200 ft Bypass), Tambaram West  
Tambaram Taluk, Chengalpattu District - 600045
3. Year of construction : Ground, First & Second Floor : RCC : 2019
4. Approximates cost of construction  
as per current rate : Rs. 680.00 Lakhs
5. Purpose for which the building  
is being used or proposed to be used : Educational Purpose
6. Purpose for which the building has  
hitherto been used : Educational Purpose
7. Details of construction of the building  
(particulars of the foundation, soil,  
Specification of various parts under : **RCC Framed Structure**  
(i) Foundation : RCC Column & Isolated Footing  
(ii) Basement : RCC Column, Plinth Beam & Brick in CM  
(iii) Superstructure : RCC Column & Brick in CM  
(iv) Floor & Roof are to be given : Flooring: Granite & Vitrified Tiles  
Roof: RCC Slab
8. Period for which the license is require : May be issued from **01.09.2022 to 31.08.2025**  
(For Three years only)
9. Number of persons to be accommodated : **One Thousand Eight Hundred (1800) Pupils only**  
Refer "ANNEXURE" to this

Place : Kancheepuram

Date : 22.07.2022

  
Signature of the Correspondent

  
Signature of the Engineer  
Er. D. NATARAJAN, B.E.,(CIVIL),MIE  
Chartered Engineer  
Panel Engineer Class 1A  
Kanchipuram District  
# 4, Vanthavasi Road,  
Gandhi Nagar,  
Kanchipuram - 631 501.  
Cell: 94431 06470, 8056631312



**ANNEXURE TO "STATEMENT ACCOMPANYING FORM – A"**

Certified that no addition or alteration has been made to the existing building or portion of a building for which this application has been made. I undertake to obtain a fresh license in case any addition or alteration is made to the existing building or portion of the building. I also undertake to obtain a fresh license if the purpose for which the license was granted for the use of the building or portion of the building originally is change or altered subsequently.

This is further to certify that no thatched buildings are used for conducting any classes within the School premises. Any thatched building constructed/used after issue of this certificate, I would be held responsible for fire accident/mishap that may occur later and that I am aware that it is a punishable crime.

*R. Achana*

Signature of the Correspondent

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,  
STRUCTURAL ENGINEER, CHARTERED ENGINEER  
REGISTERED&APPROVED ENGINEER  
BY THE BOARD OF ENGINEERS, TAMIL NADU.  
PANEL ENGINEER CLASS IA, KANCHEEPURAM DISTRICT

Res: 50-A,3<sup>rd</sup> Street, S.S. Nagar.  
Palanipet, Arakkonam – 631002

Off: No. 4, Vanthavasi Road, Gandhi Nagar,  
Kanchipuram - 631501

Cell: 9443106470, 8056631312

Email : dnatarajan8@gmail.com

FORM – B

STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

SAN ACADEMY, TAMBARAM WEST

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB SECTION (B) OF SECTION OF (4) OF SECTION 4 OF THE TAMIL NADU PUBLIC BUILDING (LICENSING ACT 1965 TAMIL NADU ACT 1 OF 1965) REFERRED TO IN RULE OF THE TAMIL NADU PUBLIC (LICENSING) RULES 1966.

I Certify, that I have inspected the building mentioned in the statement and furnished below its salient technical features.

1. **Foundation:**

- |      |  |                           |
|------|--|---------------------------|
| i.   | Depth below ground level                         | : 06ft below G.L          |
| ii.  | Nature of soil met out in the foundation         | : Brown Clayey Silty Sand |
| iii. | Pressure at foundation                           | : 10 tones / Sq.m         |
| iv.  | Probable safe bearing capacity of the foundation | : 16 tones / Sq.m         |

2. **Superstructure:**

- |     |  |   |                               |
|-----|--|---|-------------------------------|
| i.  | Maximum stress in most critical Sections of masonry and concrete | a) R.C.C Concrete : 35 Kg / Sq.cm       | b) Masonry : 08 tones / Sq.m. |
| ii. | Nature of masonry and concrete                                   | : Brick masonry in cm: 30 tones / Sq.m. |                               |
|     | And its safe permissible stress                                  | R.C.C                                   | : 40 Kg / Sq.cm.              |

The Structural of the building has been verified by me with reference to ISIS loading standards 875 (Latest version) and other relevant Indian Standard code of practices I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. This Certificate does not include any Thatched sheds and also any flammable building material utility. Proper toilet facilities to be provided as per norms. If any thatched sheds are found at a later period after issue of this certificate / License this certificate gets invalid. A license may be granted for the period from 01.09.2022 to 31.08.2025.

*R. Acham*

Signature of the Correspondent

*[Signature]*  
Signature of the Engineer  
Er. D. NATARAJAN, B.E.(CIVIL),M.I.E.  
Chartered Engineer  
Panel Engineer Class IA  
Kanchipuram District  
# 4, Vanthavasi Road,  
Gandhi Nagar,  
Kanchipuram - 631 501.  
Cell: 94431 06470, 8056631312



Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,  
STRUCTURAL ENGINEER, CHARTERED ENGINEER  
REGISTERED&APPROVED ENGINEER  
BY THE BOARD OF ENGINEERS, TAMIL NADU.  
PANEL ENGINEER CLASS IA, KANCHEEPURAM DISTRICT

Res: 50-A,3<sup>rd</sup> Street, S.S. Nagar.  
Palanipet, Arakkonam – 631002

Off: No. 4, Vanthavasi Road, Gandhi Nagar,  
Kanchipuram - 631501

Cell: 9443106470, 8056631312  
Email : dnatarajan8@gmail.com

FORM – C

STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS


SAN ACADEMY, TAMBARAM WEST

Form of certificate of structural soundness under sub section (b) of section of 4 of the madras Public Buildings (Licensing Act 1963 Madras Act 13 of 1965 referred to in rule 4 of the Madras Public building (Licensing) rules 1977.

Certify that have inspected the building mentioned in the statement below and I have satisfied myself the building is structural sound to be used as a public building for the purpose note in the statement. The structural soundness of the building has been verified taking into account the loading as per latest Indian standard 875.

Location of the building door No. street name and name of the place	Age of the building	Value of the Building	No. of Storeys	Short Description of structure steel RCC framed or load bearing masonry
1.	2.	3.	4.	5.
SAN ACADEMY Service Road (200 ft Bypass) Tambaram West Tambaram Taluk Chengalpattu District - 600045	Ground, First & Second Floor: RCC : 02 Years	Rs. 680.00 Lakhs	Ground Floor +2	RCC Framed Structure

Purpose for which the building is certified for use	The Period for which the building will be structurally sound	No of the persons to be accommodated	Remarks
6.	7.	8.	9.
Educational Purpose	License may be issued for the period of Three Years from 01.09.2022 to 31.08.2025.	1800 Pupils only	Building is structurally sound

  
Signature of the Correspondent

  
Signature of the Engineer  
Er. D. NATARAJAN, B.E.(CIVIL), M.I.E.  
Chartered Engineer  
Panel Engineer Class 1A  
Kanchipuram District  
# 4, Vanthavasi Road,  
Gandhi Nagar,  
Kanchipuram - 631 501.  
Cell: 94431 06470, 8056631312

மரம் வளர்ப்போம்.

மகழ் பெறுவோம்



**BUILDING SAFETY CERTIFICATE**

**No. 20/PE-KANCHEEPURAM**

**Dated: 22.07.2022**

Certified that the **SAN ACADEMY**, Service Road (200 ft Bypass), Tambaram West, Tambaram Taluk, Chengalpattu District - 600045. Comprised of **Ground, First & Second Floors** owned/occupied by **SAN ACADEMY**, have complied with the Building Bye Laws in accordance with rule of State/UT, and incorporate the provisions of building safety as specified in National Building Code 2005, 2016 and as amended thereafter and has been verified by the concerned officer on **21.07.2022** in the presence of **Tmt. R. Archana**, (Name and addresses of the Manager / Secretary / Correspondent or his representative, **SAN ACADEMY**, and that the said above building/premises is safe and fit for running School with effect from **01.09.2022** for a period of Three years in accordance with rules.

**Issued on 22.07.2022 at Kancheepuram by**

  
**Signature with Seal:**  
**Er. D. NATARAJAN, B.E., (CIVIL) MIE**  
Chartered Engineer  
Panel Engineer Class 1A  
Kanchipuram District  
# 4, Venthavasi Road,  
Gandhi Nagar,  
Kanchipuram - 631 501.  
Cell: 94431 06470, 8056631312